

Facility Summary in Garfield County in the City of Jordan

Location: FARMERS UNION OIL CO JORDAN  
201 Jordan Ave  
Jordan, MT 59337 Garfield

System Facility ID:17-05702

Facility Code: 21878  
Last Inspected On: 02/17/2023  
Operating Permit Renewal Date: 08/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Jordan

cenexjor@midrivers.com

Operator Contact: Robert Wilson

(406) 557-2218

cenexjor@midrivers.com

Owner/Operator: Farmers Union Oil Co Jordan

cenexjor@midrivers.com

Loren Edwards, UST Class B Global Operator  
Robert Wilson, UST Class A Operator

edwards\_loren@yahoo.com  
cenexjor@midrivers.com

Tank Code	06	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	941	Spill Test Date	02/17/2023	Piping Installed Date	09/18/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/23/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	09/18/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type	Franklin Fueling Systems/				
Tank Code	07	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	942	Spill Test Date	02/17/2023	Piping Installed Date	10/02/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4100	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					
Tank Code	08	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	943	Spill Test Date	02/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/11/2022	Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4100	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					
Tank Code	09	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	944	Spill Test Date	02/17/2023	Piping Installed Date	10/02/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3760	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					
Tank Code	10	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	945	Spill Test Date	02/17/2023	Piping Installed Date	06/03/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7900	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					
Tank Code	11	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	946	Spill Test Date	02/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/11/2022	Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4100	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					

Facility Summary in Garfield County in the City of Jordan

Location: FARMERS UNION OIL CO JORDAN 2  
40 Brusett Rd  
Jordan, MT 59337 Garfield

System Facility ID:60-15243

Facility Code: 30960  
Last Inspected On: 02/17/2023  
Operating Permit Renewal Date: 07/05/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Jordan

cenexjor@midrivers.com

Operator Contact: Robert Wilson

(406) 557-2218

cenexjor@midrivers.com

Owner/Operator: Farmers Union Oil Co Jordan

cenexjor@midrivers.com

Loren Edwards, UST Class B Global Operator  
Robert Wilson, UST Class A Operator

edwards\_loren@yahoo.com  
cenexjor@midrivers.com

Tank Code	S1	Tank Age	11	Tank Installed Date	10/28/2014	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5498	Spill Test Date		Piping Installed Date	10/28/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/02/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	11	Tank Installed Date	10/28/2014	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5499	Spill Test Date		Piping Installed Date	10/28/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/02/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	11	Tank Installed Date	10/28/2014	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	5500	Spill Test Date		Piping Installed Date	10/28/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/02/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Garfield County in the City of Jordan

Location: JAKES PLACE  
618 Jordan Ave  
Jordan, MT 59337 Garfield

System Facility ID:17-10707

Facility Code: 21895  
Last Inspected On: 08/07/2023  
Operating Permit Renewal Date: 11/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jakes Property Investments LLC(406) 853-1732skylarharbaugh@hotmail.com

Operator Contact: Kenneth Ellington;Rex Phipps;Skylar Harbaugh(406) 853-1732kellington@middrivers.com;rex@garfieldcountybank.com;skylarharbaugh@hotmail.com

Owner/Operator: Jakes Property Investments LLC(406) 853-1732skylarharbaugh@hotmail.com

Kenneth Ellington, UST Class A Operator  
Kenneth Ellington, UST Class A Operator  
Kenneth Ellington, UST Class B Operator  
Kenneth Ellington, UST Class B Operator  
Rex Phipps, UST Class A Operator  
Rex Phipps, UST Class A Operator  
Rex Phipps, UST Class B Operator  
Rex Phipps, UST Class B Operator  
Skylar Harbaugh, UST Class A Operator  
Skylar Harbaugh, UST Class A Operator  
Skylar Harbaugh, UST Class B Global Operator  
Skylar Harbaugh, UST Class B Global Operator

kellington@middrivers.com  
kellington@middrivers.com  
kellington@middrivers.com  
kellington@middrivers.com  
rex@garfieldcountybank.com  
rex@garfieldcountybank.com  
rex@garfieldcountybank.com  
rex@garfieldcountybank.com  
skylarharbaugh@hotmail.com  
skylarharbaugh@hotmail.com  
skylarharbaugh@hotmail.com  
skylarharbaugh@hotmail.com

Tank Code	05	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4311	Spill Test Date	08/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/17/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/07/2023	Line Tightness Test Date	08/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	06	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	4312	Spill Test Date	08/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/17/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/07/2023	Line Tightness Test Date	08/27/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	07	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4313	Spill Test Date	08/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/17/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/07/2023	Line Tightness Test Date	08/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Incon/TS-550 EVO				