

Facility Summary in Silver Bow County in the City of Butte

Location: ACADIA BUILDING
55 Basin Creek Rd
Butte, MT 59701-9704 Silver Bow

System Facility ID:47-00458

Facility Code: 28332
Last Inspected On: 04/19/2022
Operating Permit Renewal Date: 09/21/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Dept of Corrections (406) 444-6551 JCHRISTOFFERSON@MT.GOV

Operator Contact: Bill English;Leon Huizinga;Todd Skartved (406) 496-6329;(406) 498-4550;(406) 782-2143 hbigbearmt@aol.com;leon.huizinga@acadiahealthcare.com;milehi
ghpetro@gmail.com

Owner/Operator: Montana Dept of Corrections (406) 444-6551 JCHRISTOFFERSON@MT.GOV

Bill English, UST Class A Operator
Bill English, UST Class B Global Operator
Leon Huizinga, UST Class A Operator
Leon Huizinga, UST Class B Operator
Todd Skartved, UST Class A Operator

hbigbearmt@aol.com
hbigbearmt@aol.com
leon.huizinga@acadiahealthcare.com
leon.huizinga@acadiahealthcare.com
milehighpetro@gmail.com

Tank Code	01	Tank Age	38	Tank Installed Date	06/22/1987	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	3974	Spill Test Date	04/19/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	04/19/2022	Line Tightness Test Date	08/12/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	No
		Overfill Test Date	04/19/2022			ATG Type	Veeder Root/TLS-300				

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE MAIN CENTRAL OFFICE
200 W Broadway St
Butte, MT 59701-9226 Silver Bow

System Facility ID:56-14034

Facility Code: 30690
Last Inspected On: 10/12/2022
Operating Permit Renewal Date: 10/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Century Link Communication (501) 680-8141 Stephanie.miller@lumen.com

Operator Contact: Stephanie Miller (501) 680-8141 Stephanie.miller@lumen.com

Owner/Operator: Century Link Communication (501) 680-8141 Stephanie.miller@lumen.com

Stephanie Miller, UST Class A Operator

Stephanie.miller@lumen.com

Stephanie Miller, UST Class B Global Operator

Stephanie.miller@lumen.com

Tank Code	01	Tank Age	23	Tank Installed Date	10/02/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4732	Spill Test Date	10/04/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/27/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2500	ATG Test Date	10/04/2022	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/04/2022			ATG Type					

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE SCHOOL DIST 1 BUS BARN
1220 E Front St
Butte, MT 59701-2936 Silver Bow

System Facility ID:47-01980

Facility Code: 28355
Last Inspected On: 09/29/2022
Operating Permit Renewal Date: 01/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	School Dist 1 Butte	(406) 496-2185	
Operator Contact:	Bill English;Jed Johnson;Leonard Diaz;Todd Skartved	(406) 498-4550;(406) 782-2143	hbigbearmt@aol.com;jedjohnson86@yahoo.com;leonard.diaz@rsd.k12.az.us;milehighpetro@gmail.com

Owner/Operator: School Dist 1 Butte (406) 496-2185

Bill English, UST Class A Operator	hbigbearmt@aol.com
Bill English, UST Class A Operator	hbigbearmt@aol.com
Bill English, UST Class B Global Operator	hbigbearmt@aol.com
Bill English, UST Class B Global Operator	hbigbearmt@aol.com
Jed Johnson, UST Class A Operator	jedjohnson86@yahoo.com
Jed Johnson, UST Class A Operator	jedjohnson86@yahoo.com
Jed Johnson, UST Class B Global Operator	jedjohnson86@yahoo.com
Jed Johnson, UST Class B Global Operator	jedjohnson86@yahoo.com
Leonard Diaz, UST Class A Operator	leonard.diaz@rsd.k12.az.us
Leonard Diaz, UST Class A Operator	leonard.diaz@rsd.k12.az.us
Leonard Diaz, UST Class B Operator	leonard.diaz@rsd.k12.az.us
Leonard Diaz, UST Class B Operator	leonard.diaz@rsd.k12.az.us
Todd Skartved, UST Class A Operator	milehighpetro@gmail.com
Todd Skartved, UST Class B Global Operator	milehighpetro@gmail.com

Tank Code	03	Tank Age	33	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1892	Spill Test Date	09/29/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	09/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/29/2022			ATG Type	Gilbarco/EMC Basic;Gilbarco- Veeder Root/EMC Basic				
--	--	--------------------	------------	--	--	----------	---	--	--	--	--

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE SILVER BOW MAINTENANCE CENTER
1700 Civic Center Rd
Butte, MT 59701-4857 Silver Bow

System Facility ID:47-08477

Facility Code: 28444
Last Inspected On: 01/16/2019
Operating Permit Renewal Date: 06/09/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte Silver Bow County		
Operator Contact:	Jed Johnson;John Stajcar;Todd Skartved	(406) 497-6569;(406) 498-4550
		jedjohnson86@yahoo.com;jstajcar@bsb.mt.gov;milehighpetro@gmail.com

Jed Johnson, UST Class A Operator
Jed Johnson, UST Class B Global Operator
John Stajcar, UST Class A Operator
John Stajcar, UST Class B Global Operator
Todd Skartved, UST Class A Operator
Todd Skartved, UST Class B Global Operator

jedjohnson86@yahoo.com
jedjohnson86@yahoo.com
jstajcar@bsb.mt.gov
jstajcar@bsb.mt.gov
milehighpetro@gmail.com
milehighpetro@gmail.com

Tank Code	06	Tank Age	28	Tank Installed Date	01/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	511	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	01/16/2019	Sump Tightness Test Date	10/01/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date	05/04/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	07	Tank Age	28	Tank Installed Date	01/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	512	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	01/16/2019	Sump Tightness Test Date	10/01/2015	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	30000	ATG Test Date		Line Tightness Test Date	05/04/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE'S HOMETOWN AUTO REPAIR
910 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-01835

Facility Code: 28353
Last Inspected On: 03/17/2020
Operating Permit Renewal Date: 03/17/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bigheads Inc;Catherine Shea(406) 782-2812bigheadsinc@hotmail.com

Operator Contact: Jake Perusichbuttehometownautorepair@yahoo.com

Jake Perusich, UST Class A Operator						buttehometownautorepair@yahoo.com					
Jake Perusich, UST Class B Global Operator						buttehometownautorepair@yahoo.com					
Tank Code	07	Tank Age	26	Tank Installed Date	02/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3959	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	08	Tank Age	26	Tank Installed Date	02/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3960	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	09	Tank Age	26	Tank Installed Date	02/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	3961	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	16000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: CENEX ZIP TRIP 72
2801 Harrison Ave
Butte, MT 59701-3715 Silver Bow

System Facility ID:47-05148

Facility Code: 28404
Last Inspected On: 06/08/2023
Operating Permit Renewal Date: 12/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator
Jim Alford, UST Class A Operator
Jim Alford, UST Class B Operator
Jim Alford, UST Class B Operator
Luci Tuttle, UST Class B Operator
Sean Hurley, UST Class A Operator
Sean Hurley, UST Class A Operator
Travis Weber, UST Class B Operator

jim.alford@chsinc.com
jim.alford@chsinc.com
jim.alford@chsinc.com
jim.alford@chsinc.com
Lucinda.Tuttle@chsinc.com
sean.hurley@chsinc.com
sean.hurley@chsinc.com
travis.weber3@chsinc.com

Tank Code	08	Tank Age	35	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1707	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	35	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1708	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	12000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	35	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1709	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	35	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1710	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	35	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1711	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: CENEX ZIP TRIP 73
848 W Park St
Butte, MT 59701-9066 Silver Bow

System Facility ID:47-00386

Facility Code: 28330
Last Inspected On: 02/24/2025
Operating Permit Renewal Date: 05/16/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator
Jim Alford, UST Class A Operator
Jim Alford, UST Class B Operator
Jim Alford, UST Class B Operator
Luci Tuttle, UST Class B Operator
Sean Hurley, UST Class A Operator
Sean Hurley, UST Class A Operator
Travis Weber, UST Class B Operator

jim.alford@chsinc.com
jim.alford@chsinc.com
jim.alford@chsinc.com
jim.alford@chsinc.com
Lucinda.Tuttle@chsinc.com
sean.hurley@chsinc.com
sean.hurley@chsinc.com
travis.weber3@chsinc.com

Tank Code	05	Tank Age	27	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4425	Spill Test Date	10/05/2021	Piping Installed Date	05/15/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/22/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/04/2022	Line Tightness Test Date	01/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	27	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4426	Spill Test Date	10/05/2021	Piping Installed Date	05/15/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	05/22/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/04/2022	Line Tightness Test Date	01/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	27	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4427	Spill Test Date	10/05/2021	Piping Installed Date	05/15/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/22/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	08/04/2022	Line Tightness Test Date	01/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: DETENTION CENTER
155 W Quartz St
Butte, MT 59701-9200 Silver Bow

System Facility ID:56-14119

Facility Code: 30760
Last Inspected On: 02/06/2023
Operating Permit Renewal Date: 05/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte Silver Bow County		
Operator Contact:	Bill English;Jed Johnson;John Stajcar	(406) 497-6569;(406) 782-2143
		hbigbearmt@aol.com;jedjohnson86@yahoo.com;jstajcar@bsb.mt.gov

Owner/Operator: Butte Silver Bow County

Bill English, UST Class A Operator
Bill English, UST Class B Global Operator
Jed Johnson, UST Class A Operator
John Stajcar, UST Class A Operator

hbigbearmt@aol.com
hbigbearmt@aol.com
jedjohnson86@yahoo.com
jstajcar@bsb.mt.gov

Tank Code	01	Tank Age	20	Tank Installed Date	01/31/2005	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5006	Spill Test Date	11/08/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/23/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	02/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Silver Bow County in the City of Butte

Location: FED EX DISTRIBUTION
119771 Rick Jones Way
Butte, MT 59750 Silver Bow

System Facility ID:60-15178

Facility Code: 30904
Last Inspected On: 11/27/2023
Operating Permit Renewal Date: 04/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Arc Febttmt 001 LLC			(215) 449-3600		
Operator Contact: Brenden Rose;Arc Febttmt 001 LLC;Chong Lee;Greg Peters			(215) 449-3600;(408) 654-3112		
			Brenden.Rose@fedex.com;chong.lee@fedex.com;greg.peters@fedex.com		

Owner/Operator: Arc Febttmt 001 LLC			(215) 449-3600		
Brenden Rose, UST Class A Operator			Brenden.Rose@fedex.com		
Brenden Rose, UST Class B Operator			Brenden.Rose@fedex.com		
Chong Lee, UST Class A Operator			chong.lee@fedex.com		
Greg Peters, UST Class A Operator			greg.peters@fedex.com		
Greg Peters, UST Class B Operator			greg.peters@fedex.com		

Tank Code	01	Tank Age	14	Tank Installed Date	03/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5286	Spill Test Date	11/28/2023	Piping Installed Date	12/20/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/27/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	10/05/2023	Line Tightness Test Date	07/10/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: HOLLOW CONSTRUCTION
404 W Greenwood Ave
Butte, MT 59701-2898 Silver Bow

System Facility ID:47-05359

Facility Code: 28410
Last Inspected On: 01/23/2024
Operating Permit Renewal Date: 05/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Hollow Contracting;William Hollow	(406) 782-6033
Operator Contact:	Susan Lasher	slasher@hollowcontracting.com

Owner/Operator:	Hollow Contracting	(406) 782-6033
Owner/Operator:	William J Hollow	(406) 782-6033
	Susan Lasher, UST Class A Operator	slasher@hollowcontracting.com
	Susan Lasher, UST Class B Operator	slasher@hollowcontracting.com

Tank Code	02	Tank Age	25	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4162	Spill Test Date	04/30/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/25/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date	04/04/2024	Line Tightness Test Date	04/30/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2024			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	03	Tank Age	25	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4163	Spill Test Date	04/30/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/25/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/25/2023	Line Tightness Test Date	04/30/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2024			ATG Type	Gilbarco-Veeder Root/EMC Basic				

Tank Code	04	Tank Age	25	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4164	Spill Test Date	04/30/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/25/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/25/2023	Line Tightness Test Date	04/30/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2024			ATG Type	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: JMT CORP MONTANA DBA JMT TRISTOP AND CASINO
2544 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-05202

Facility Code: 28406
Last Inspected On: 05/12/2023
Operating Permit Renewal Date: 08/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JMT Corp Montana (406) 782-9359 jmann@jmtpetro.com

Operator Contact:

Owner/Operator: JMT Corp Montana (406) 782-9359 jmann@jmtpetro.com

Tank Code	06	Tank Age	35	Tank Installed Date	03/08/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1546	Spill Test Date	04/24/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/24/2023	Line Tightness Test Date	07/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	35	Tank Installed Date	03/08/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1547	Spill Test Date	04/24/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/24/2023	Line Tightness Test Date	07/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	08	Tank Age	30	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1548	Spill Test Date	04/24/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/24/2023	Line Tightness Test Date	07/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	30	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1549	Spill Test Date	04/24/2023	Piping Installed Date	02/12/2021	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/24/2023	Line Tightness Test Date	07/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: MDOT BUTTE
3751 Wynne Ave
Butte, MT 59701-6712 Silver Bow

System Facility ID:47-01062

Facility Code: 28342
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Operator Contact: Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Walt Kerttula;Montana Department of Transportation Helena (406) 444-6151;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632 jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;wkerttula@mt.gov

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Charles Stratford, UST Class B Operator
Joe Radonich, UST Class A Operator
Joe Radonich, UST Class B Operator
Mike Murolo, UST Class A Operator
Paul Jordan, UST Class B Operator
Walt Kerttula, UST Class A Operator
cstratford@mt.gov
jradonich@mt.gov
jradonich@mt.gov
jradonich@mt.gov
pjordan@mt.gov
wkerttula@mt.gov

Tank Code	08	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2937	Spill Test Date	05/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/01/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	09	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2938	Spill Test Date	05/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/09/2024			ATG Type	Gilbarco/EMC Basic				
--	--	--------------------	------------	--	--	----------	-----------------------	--	--	--	--

Facility Summary in Silver Bow County in the City of Butte

Location: MONTANA RESOURCES INC
600 Shields Ave
Butte, MT 59701-2705 Silver Bow

System Facility ID:47-13549

Facility Code: 28507
Last Inspected On: 11/14/2023
Operating Permit Renewal Date: 03/05/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Montana Resources LLC	(406) 723-9542	jfleege@montanaresources.com
Operator Contact:	Jeremy Fleege;Thomas Dale	(406) 498-8360	jfleege@jbrenv.com

Owner/Operator:	Montana Resources LLC	(406) 723-9542	jfleege@montanaresources.com
	Daniel Lorengo, UST Class B Operator		dlorenco@montanaresources.com
	Jeremy Fleege, UST Class A Operator		jfleege@jbrenv.com
	Jerry Frohreich, UST Class B Operator		jfrohreich@montanaresources.com
	Jody D'Arcy, UST Class B Operator		drc2251@hotmail.com
	Thomas Dale, UST Class A Operator		
	Thomas Dale, UST Class B Operator		

Tank Code	02	Tank Age	28	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1687	Spill Test Date	11/14/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/14/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Gravity Feed	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/14/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: NORTHWEST PETROLEUM FACILITY
28 Dewey Blvd
Butte, MT 59701-3195 Silver Bow

System Facility ID:56-14033

Facility Code: 30689
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Northwest Petroleum Co	(406) 497-6700	done@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Northwest Petroleum Co	(406) 497-6700	done@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	01	Tank Age	23	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4639	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	23	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4640	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	25000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	23	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4641	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	23	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4642	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	23	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4643	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	08/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	23	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4644	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	23	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4645	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	23	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4646	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/14/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: RD'S QUICK FUEL
16 E Dewey Blvd
Butte, MT 59701-3195 Silver Bow

System Facility ID:47-13531

Facility Code: 28506
Last Inspected On: 08/10/2022
Operating Permit Renewal Date: 12/05/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC (406) 294-0865 tamara.noble@cityservicevalcon.com

Operator Contact: Kary Tonjum

Owner/Operator: City Service Valcon LLC (406) 294-0865 tamara.noble@cityservicevalcon.com

Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Operator
Kary Tonjum, UST Class B Operator
Mitchell Kilmer, UST Class B Operator
Mitchell Kilmer, UST Class B Operator
Roy Morris, UST Class B Global Operator
Roy Morris, UST Class B Global Operator

mkilmer@bresnan.net
mkilmer@bresnan.net
roy@morris-marketing.com
roy@morris-marketing.com

Tank Code	01	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1712	Spill Test Date	12/08/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1713	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/19/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	20000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	03	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1714	Spill Test Date	12/08/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/19/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	04	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1715	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/19/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	05	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1716	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	06	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1717	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	07	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1718	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Incon/TS-550 EVO				

Facility Summary in Silver Bow County in the City of Butte

Location: SILVER BOW COUNTY PUBLIC WORKS
Browns Gulch
Butte, MT 59701 Silver Bow

System Facility ID:47-13157

Facility Code: 28500
Last Inspected On: 03/10/2025
Operating Permit Renewal Date: 06/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Silver Bow County Browns Gulch Landfill (406) 497-6569

Operator Contact: Todd Skartved (406) 498-4550 milehighpetro@gmail.com

Owner/Operator: Silver Bow County Browns Gulch Landfill (406) 497-6569

Todd Skartved, UST Class A Operator
Todd Skartved, UST Class B Global Operator

milehighpetro@gmail.com
milehighpetro@gmail.com

Tank Code	01	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4465	Spill Test Date	10/29/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	03/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/24/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: ST JAMES HEALTHCARE INC
400 S Clark St
Butte, MT 59701-2328 Silver Bow

System Facility ID:47-06924

Facility Code: 28426
Last Inspected On: 09/29/2022
Operating Permit Renewal Date: 12/05/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: St James Healthcare Inc

Operator Contact: Thomas McKenna (406) 723-2747 tmckennaco@icloud.com

Owner/Operator: St James Healthcare Inc

Mark McGivern, UST Class B Operator
Richard Giuffra, UST Class B Operator
Thomas McKenna, UST Class A Operator
Thomas McKenna, UST Class B Global Operator

mark.mcgivern@sclhealth.org
richard.giuffra@imail2.org
tmckennaco@icloud.com
tmckennaco@icloud.com

Tank Code	05	Tank Age	24	Tank Installed Date	05/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4449	Spill Test Date	11/11/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/11/2021	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/17/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/17/2023	Line Tightness Test Date	01/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: THREE BEARS ALASKA
45 Three Bears Dr
Butte, MT 59701-7171 Silver Bow

System Facility ID:60-15058

Facility Code: 30832
Last Inspected On: 11/21/2022
Operating Permit Renewal Date: 01/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	FIP Master Funding II, LLC	(602) 448-5226	matt@fundamentalincome.com
Operator Contact:	Dave Goody;Lindsay Myers;Wendy Whelchel	(406) 494-7547	lmyers@threebearsalaska.com;lmyers@threebearsalaska.com;store70@threebearsalaska.com

Owner/Operator: FIP Master Funding II, LLC

(602) 448-5226

matt@fundamentalincome.com

Dave Goody, UST Class A Operator

store70@threebearsalaska.com

Lindsay Myers, UST Class A Operator

lmyers@threebearsalaska.com

Lindsay Myers, UST Class B Operator

lmyers@threebearsalaska.com

Wendy Whelchel, UST Class A Operator

lmyers@threebearsalaska.com

Tank Code	01	Tank Age	18	Tank Installed Date	04/24/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5103	Spill Test Date	11/21/2022	Piping Installed Date	10/25/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	17000	ATG Test Date	09/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	18	Tank Installed Date	04/24/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5104	Spill Test Date	11/21/2022	Piping Installed Date	10/25/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/21/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/11/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 1
3501 Harrison Ave
Butte, MT 59701-3547 Silver Bow

System Facility ID:47-07932

Facility Code: 28433
Last Inspected On: 03/07/2025
Operating Permit Renewal Date: 05/06/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey (406) 491-5808;(406) 494-2305 ldsutey66@thriftwayss.com;otonicarlinda@aol.com

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Cindy Beck, UST Class B Operator
Jack Hook, UST Class A Operator
Jack Hook, UST Class B Global Operator
Jack Hook, UST Class B Operator
James Brown, UST Class B Operator
Linda Otonicar, UST Class A Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator
Shelby Hart, UST Class B Operator

thriftway1@thriftwayss.com

dsbrown@ttc-cmc.net
otonicarlinda@aol.com
ldsutey66@thriftwayss.com
ldsutey66@thriftwayss.com
srandall59701@gmail.com

Tank Code	07	Tank Age	35	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2062	Spill Test Date	03/06/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	14783	ATG Test Date	12/04/2024	Line Tightness Test Date	09/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	35	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2063	Spill Test Date	12/04/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	04/03/2024	Line Tightness Test Date	08/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	35	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2064	Spill Test Date	12/04/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/04/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	04/03/2024	Line Tightness Test Date	08/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	35	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2065	Spill Test Date	12/04/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/04/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5929	ATG Test Date	04/03/2024	Line Tightness Test Date	09/05/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	35	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2066	Spill Test Date	12/04/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/04/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5929	ATG Test Date	04/03/2024	Line Tightness Test Date	09/19/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 16
4701 Harrison Ave
Butte, MT 59701-7002 Silver Bow

Facility Code: 28486
Last Inspected On: 06/28/2022
System Facility ID:47-10657
Operating Permit Renewal Date: 07/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Operator Contact: Linda Otonicar,Louis Sutey (406) 491-5808;(406) 494-2305 ldsutey66@thriftwayss.com;otonicarlinda@aol.com

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com
Geoff Gifford, UST Class B Operator Thriftway16@Thriftwayss.com
Linda Otonicar, UST Class A Operator otonicarlinda@aol.com
Louis Sutey, UST Class A Operator ldsutey66@thriftwayss.com

Tank Code	01	Tank Age	38	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1921	Spill Test Date	03/18/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/28/2022	Tank/Piping CP Test Date	10/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/04/2023	Line Tightness Test Date	02/10/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	38	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1922	Spill Test Date	03/18/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/28/2022	Tank/Piping CP Test Date	10/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/04/2023	Line Tightness Test Date	02/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	38	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1923	Spill Test Date	03/18/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/28/2022	Tank/Piping CP Test Date	10/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	01/04/2023	Line Tightness Test Date	02/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	38	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1924	Spill Test Date	03/18/2022	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/28/2022	Tank/Piping CP Test Date	10/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	01/04/2023	Line Tightness Test Date	02/12/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 2
1900 S Montana St
Butte, MT 59701-3023 Silver Bow

System Facility ID:47-07935

Facility Code: 28436
Last Inspected On: 05/01/2025
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey (406) 491-5808;(406) 494-2305 ldsutey66@thriftwayss.com;otonicarlinda@aol.com

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Jack Hook, UST Class A Operator
Jessica Willis, UST Class B Global Operator
Linda Otonicar, UST Class A Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator

clownprincess269@gmail.com
otonicarlinda@aol.com
ldsutey66@thriftwayss.com
ldsutey66@thriftwayss.com

Tank Code	04	Tank Age	36	Tank Installed Date	05/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2070	Spill Test Date	02/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	06/13/2022	Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	06/30/2022	Line Tightness Test Date	04/15/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	36	Tank Installed Date	05/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2071	Spill Test Date	02/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	06/13/2022	Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	06/30/2022	Line Tightness Test Date	04/15/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	36	Tank Installed Date	05/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2072	Spill Test Date	02/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	06/13/2022	Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	06/30/2022	Line Tightness Test Date	04/15/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 4
2610 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-07934

Facility Code: 28435
Last Inspected On: 05/02/2025
Operating Permit Renewal Date: 06/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	David Sutey;Sutey Oil Co Inc	(406) 494-2305	ldsutey66@thriftwayss.com
Operator Contact:	Geoff Gifford;Jack Hook;Linda Otonicar;Louis Sutey	(406) 491-5808;(406) 494-2305;(406) 494-3155	ldsutey66@thriftwayss.com;otonicarlinda@aol.com;Thriftway16@Thriftwayss.com

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Geoff Gifford, UST Class A Operator

Jack Hook, UST Class A Operator

Jack Hook, UST Class A Operator

Kasey Maes, UST Class B Operator

Kasey Maes, UST Class B Operator

Linda Otonicar, UST Class A Operator

Linda Otonicar, UST Class B Global Operator

Louis Sutey, UST Class A Operator

Louis Sutey, UST Class B Global Operator

Thriftway16@Thriftwayss.com

maeskasey@gmail.com

maeskasey@gmail.com

otonicarlinda@aol.com

otonicarlinda@aol.com

ldsutey66@thriftwayss.com

ldsutey66@thriftwayss.com

Tank Code	05	Tank Age	35	Tank Installed Date	03/13/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2067	Spill Test Date	12/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/26/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	04/26/2022	Line Tightness Test Date	01/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Veeder Root/TLS-350				
Tank Code	06	Tank Age	35	Tank Installed Date	03/13/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2068	Spill Test Date	12/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	04/26/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	04/26/2022	Line Tightness Test Date	01/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Veeder Root/TLS-350				
Tank Code	07	Tank Age	35	Tank Installed Date	03/13/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2069	Spill Test Date	12/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/26/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	04/26/2022	Line Tightness Test Date	01/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Veeder Root/TLS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 5
901 E Front St
Butte, MT 59701-2929 Silver Bow

System Facility ID:47-00942

Facility Code: 28334
Last Inspected On: 01/22/2025
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	David Sutey;Sutey Oil Co Inc	(406) 494-2305	ldsutey66@thriftwayss.com
Operator Contact:	Jack Hook;Linda Otonicar;Louis Sutey	(406) 491-5808;(406) 494-2305	ldsutey66@thriftwayss.com;otonicarlinda@aol.com

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Allen Beagley, UST Class B Global Operator	thriftway5@thriftwayss.com
Allen Beagley, UST Class B Global Operator	thriftway5@thriftwayss.com
Allen Beagley, UST Class B Operator	thriftway5@thriftwayss.com
Allen Beagley, UST Class B Operator	thriftway5@thriftwayss.com
Jack Hook, UST Class A Operator	
Jack Hook, UST Class A Operator	
Jack Hook, UST Class B Global Operator	
Jack Hook, UST Class B Global Operator	
Jack Hook, UST Class B Operator	
Jack Hook, UST Class B Operator	
Katie Black, UST Class B Operator	katie.black1369@gmail.com
Kenneth Beck, UST Class B Global Operator	suesman@hotmail.com
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Linda Otonicar, UST Class B Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Robert Osmanson, UST Class B Operator	bobby.osmanson@yahoo.com
Robert Osmanson, UST Class B Operator	bobby.osmanson@yahoo.com

Tank Code	05	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2059	Spill Test Date	01/22/2025	Piping Installed Date	11/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	02/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/11/2022	Line Tightness Test Date	08/16/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/22/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2060	Spill Test Date	01/22/2025	Piping Installed Date	11/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	02/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/11/2022	Line Tightness Test Date	11/18/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/22/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	31	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2061	Spill Test Date	01/22/2025	Piping Installed Date	11/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	02/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/11/2022	Line Tightness Test Date	08/20/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/22/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 6
2401 Continental Dr
Butte, MT 59701-6562 Silver Bow

System Facility ID:47-07936

Facility Code: 28437
Last Inspected On: 10/29/2024
Operating Permit Renewal Date: 02/27/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	David Sutey;Sutey Oil Co Inc	(406) 494-2305	ldsutey66@thriftwayss.com
Operator Contact:	Jack Hook;Ken Beck;Linda Otonicar;Louis Sutey	(406) 491-5808;(406) 494-2305;(406) 723-2022	ldsutey66@thriftwayss.com;otonicarlinda@aol.com;suesman@hotmail.com

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Dean Brown, UST Class B Operator	twaydb36016@gmail.com
Jack Hook, UST Class A Operator	
Jack Hook, UST Class B Global Operator	
Jack Hook, UST Class B Operator	
Jessica Willis, UST Class B Global Operator	clownprincess269@gmail.com
Ken Beck, UST Class A Operator	suesman@hotmail.com
Ken Beck, UST Class B Operator	suesman@hotmail.com
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Marianne Taylor, UST Class B Operator	thriftway2@thriftwayss.com
Tracy Brown, UST Class B Operator	ldsutey66@thriftwayss.com

Tank Code	01	Tank Age	57	Tank Installed Date	05/07/1968	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2073	Spill Test Date	10/29/2024	Piping Installed Date	06/23/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	04/11/2024	Tank/Piping CP Test Date	04/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/11/2024	Line Tightness Test Date	01/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	02	Tank Age	57	Tank Installed Date	05/07/1968	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2074	Spill Test Date	10/29/2024	Piping Installed Date	06/23/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	04/11/2024	Tank/Piping CP Test Date	04/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/11/2024	Line Tightness Test Date	01/21/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	52	Tank Installed Date	05/07/1973	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2075	Spill Test Date	10/29/2024	Piping Installed Date	06/23/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	04/11/2024	Tank/Piping CP Test Date	04/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/11/2024	Line Tightness Test Date	01/19/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP BUTTE #5
2305 Continental Dr
Butte, MT 59701 Silver Bow

System Facility ID:60-15187

Facility Code: 30912
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/31/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Butte 5 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Butte 5 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	01	Tank Age	14	Tank Installed Date	11/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5310	Spill Test Date	10/02/2024	Piping Installed Date	07/28/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/26/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/02/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	14	Tank Installed Date	11/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5311	Spill Test Date	06/07/2024	Piping Installed Date	07/28/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	06/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	14	Tank Installed Date	11/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5312	Spill Test Date	06/07/2024	Piping Installed Date	07/28/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/07/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/26/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 1
1370 Harrison Ave
Butte, MT 59701-4848 Silver Bow

System Facility ID:47-08679

Facility Code: 28450
Last Inspected On: 08/29/2022
Operating Permit Renewal Date: 09/19/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Butte 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Butte 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	05	Tank Age	37	Tank Installed Date	04/11/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2618	Spill Test Date	10/07/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/01/2023	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	39	Tank Installed Date	04/11/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2619	Spill Test Date	10/07/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/01/2023	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	8000	ATG Test Date	05/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	37	Tank Installed Date	04/11/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2620	Spill Test Date	10/07/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/01/2023	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/07/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	34	Tank Installed Date	07/28/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2621	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/01/2023	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 10
901 N Excelsior Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-08687

Facility Code: 28458
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/03/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Butte 10 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Butte 10 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	01	Tank Age	54	Tank Installed Date	04/12/1971	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2633	Spill Test Date	10/31/2024	Piping Installed Date	11/01/2019	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/26/2025	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	04/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	54	Tank Installed Date	04/12/1971	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2634	Spill Test Date	04/17/2024	Piping Installed Date	11/01/2019	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/26/2025	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	4000	ATG Test Date	03/26/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	04/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 2
531 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-08680

Facility Code: 28451
Last Inspected On: 08/22/2022
Operating Permit Renewal Date: 02/09/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Butte 2 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Butte 2 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	01	Tank Age	40	Tank Installed Date	09/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2622	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/28/2020	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	05/07/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	40	Tank Installed Date	09/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2623	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/28/2020	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	05/07/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	37	Tank Installed Date	09/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2624	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/28/2020	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	05/07/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	4	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6038	Spill Test Date	06/28/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	24000	ATG Test Date	07/18/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/18/2022			ATG Type					
Tank Code	05	Tank Age	4	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6039	Spill Test Date	06/28/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	07/18/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/18/2022			ATG Type					
Tank Code	06	Tank Age	4	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6040	Spill Test Date	05/09/2024	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	07/18/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/18/2022			ATG Type					
Tank Code	07	Tank Age	4	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6041	Spill Test Date	06/28/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/18/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/18/2022			ATG Type					
Tank Code	08	Tank Age	4	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6042	Spill Test Date	06/28/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	07/18/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/18/2022			ATG Type					
Tank Code	09	Tank Age	4	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6043	Spill Test Date	06/28/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/18/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/18/2022			ATG Type					

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 3
2328 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-08682

Facility Code: 28453
Last Inspected On: 03/20/2025
Operating Permit Renewal Date: 07/27/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Butte 3 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Butte 3 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	01	Tank Age	44	Tank Installed Date	04/11/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2625	Spill Test Date	07/25/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/20/2025	Tank/Piping CP Test Date	07/25/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	07/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	35	Tank Installed Date	10/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2626	Spill Test Date	07/25/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/20/2025	Tank/Piping CP Test Date	05/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No

		Overfill Test Date	07/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	35	Tank Installed Date	10/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2627	Spill Test Date	07/25/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/20/2025	Tank/Piping CP Test Date	05/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	07/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	35	Tank Installed Date	10/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2628	Spill Test Date	07/25/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/20/2025	Tank/Piping CP Test Date	05/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	07/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 4
3700 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID:56-13911

Facility Code: 30581
Last Inspected On: 08/29/2022
Operating Permit Renewal Date: 09/15/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Butte 4 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Butte 4 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	01	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4022	Spill Test Date	10/02/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/18/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4023	Spill Test Date	04/26/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/18/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	10000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/29/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4024	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/18/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4025	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/18/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/29/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4026	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/18/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4294	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/18/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 8
2001 Dewey Blvd
Butte, MT 59701 Silver Bow

System Facility ID:47-08686

Facility Code: 28457
Last Inspected On: 10/20/2022
Operating Permit Renewal Date: 10/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 8 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trent Biggers, UST Class B Global Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Trentb@townpump.com

Trentb@townpump.com

Trentb@townpump.com

Trentb@townpump.com

Tank Code	01	Tank Age	44	Tank Installed Date	10/01/1981	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2629	Spill Test Date	07/20/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/10/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	120000	ATG Test Date	08/10/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	48	Tank Installed Date	01/01/1977	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2631	Spill Test Date	07/20/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/20/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	48000	ATG Test Date	08/10/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	44	Tank Installed Date	10/01/1981	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2632	Spill Test Date	07/20/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/10/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	48000	ATG Test Date	08/10/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	44	Tank Installed Date	10/01/1981	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4265	Spill Test Date	07/20/2021	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	01/30/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/20/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	120000	ATG Test Date	08/10/2022	Line Tightness Test Date	01/30/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Silver Bow County in the City of Melrose

Location: MELROSE BAR
120 Main St
Melrose, MT 59743 Silver Bow

System Facility ID:47-07486

Facility Code: 28431
Last Inspected On: 11/15/2023
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Melrose License Holdings LLC;Rebecca Mergenthaler (406) 443-3360;(406) 799-3577 melrosebar@yahoo.com

Operator Contact: Lee Lively;Rebecca Mergenthaler (406) 799-3577 brkcano@3rivers.net;melrosebar@yahoo.com

Owner/Operator: Melrose License Holdings LLC (406) 443-3360 melrosebar@yahoo.com

Owner/Operator: Rebecca Mergenthaler (406) 443-3360 melrosebar@yahoo.com

Lee Lively, UST Class A Operator brkcano@3rivers.net

Lee Lively, UST Class A Operator brkcano@3rivers.net

Lee Lively, UST Class B Operator brkcano@3rivers.net

Lee Lively, UST Class B Operator brkcano@3rivers.net

Rebecca Mergenthaler, UST Class A Operator melrosebar@yahoo.com

Rebecca Mergenthaler, UST Class A Operator melrosebar@yahoo.com

Rebecca Mergenthaler, UST Class B Operator melrosebar@yahoo.com

Rebecca Mergenthaler, UST Class B Operator melrosebar@yahoo.com

Tank Code	01	Tank Age	42	Tank Installed Date	05/08/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4054	Spill Test Date	11/09/2021	Piping Installed Date	08/16/2011	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/20/2023	Sump Tightness Test Date	11/09/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/18/2022	Tank/Piping CP Test Date	02/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2023	Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	42	Tank Installed Date	05/08/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4055	Spill Test Date	11/09/2021	Piping Installed Date	08/16/2011	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	07/20/2023	Sump Tightness Test Date	11/09/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/18/2022	Tank/Piping CP Test Date	02/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/20/2023	Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Rocker

Location: ROCKER FLYING J
122000 N Browns Gulch Rd
Rocker, MT 59701 Silver Bow

System Facility ID:47-09893

Facility Code: 28472
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 11/11/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Rocker 3 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Rocker 3 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	15	Tank Age	13	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5302	Spill Test Date	04/16/2024	Piping Installed Date	04/12/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	03/27/2025	Line Tightness Test Date	09/06/2014	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	16	Tank Age	13	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5303	Spill Test Date	08/01/2024	Piping Installed Date	08/26/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	03/27/2025	Line Tightness Test Date	09/06/2014	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	17	Tank Age	13	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5304	Spill Test Date	04/16/2024	Piping Installed Date	08/26/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	03/27/2025	Line Tightness Test Date	09/06/2014	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	18	Tank Age	13	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5305	Spill Test Date	04/16/2024	Piping Installed Date	08/26/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	19	Tank Age	13	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5306	Spill Test Date	04/16/2024	Piping Installed Date	07/25/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel, Dyed	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	20	Tank Age	13	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5307	Spill Test Date	08/01/2024	Piping Installed Date	07/25/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	21	Tank Age	13	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5308	Spill Test Date	04/16/2024	Piping Installed Date	07/25/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	23	Tank Age	14	Tank Installed Date	07/25/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Unknown	Overfill Types	
Tag Number	5364	Spill Test Date		Piping Installed Date	07/25/2011	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	

Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	24	Tank Age	0	Tank Installed Date	02/19/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6283	Spill Test Date	04/25/2025	Piping Installed Date	03/01/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	22000	ATG Test Date	04/25/2025	Line Tightness Test Date	03/03/2025	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/25/2025			ATG Type					
Tank Code	25	Tank Age	0	Tank Installed Date	02/19/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6284	Spill Test Date	04/25/2025	Piping Installed Date	03/01/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	04/25/2025	Line Tightness Test Date	03/03/2025	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/25/2025			ATG Type					
Tank Code	26	Tank Age	0	Tank Installed Date	02/19/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	6285	Spill Test Date	04/25/2025	Piping Installed Date	03/01/2025	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	22000	ATG Test Date	04/25/2025	Line Tightness Test Date	03/03/2025	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	04/25/2025			ATG Type					
Tank Code	27	Tank Age	0	Tank Installed Date	02/19/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6286	Spill Test Date	04/25/2025	Piping Installed Date	03/01/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline, E10	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	04/25/2025	Line Tightness Test Date	03/03/2025	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/25/2025			ATG Type					

Facility Summary in Silver Bow County in the City of Rocker

Location: TOWN PUMP INC ROCKER
1000 Grizzly Trl
Rocker, MT 59701-9646 Silver Bow

System Facility ID:47-13173

Facility Code: 28501
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 09/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Rocker 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Rocker 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	01	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2635	Spill Test Date	04/16/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2636	Spill Test Date	07/31/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date	05/13/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	12000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2637	Spill Test Date	07/31/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date	05/13/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2638	Spill Test Date	07/31/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2639	Spill Test Date	04/16/2024	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No

		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2640	Spill Test Date	04/16/2024	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2641	Spill Test Date	04/16/2024	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2642	Spill Test Date	07/31/2024	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve

Tag Number	2643	Spill Test Date	04/16/2024	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2644	Spill Test Date	04/16/2024	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	11	Tank Age	32	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2645	Spill Test Date	07/31/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	12	Tank Age	26	Tank Installed Date	06/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4103	Spill Test Date	04/16/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/27/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/27/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	13	Tank Age	13	Tank Installed Date	11/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5375	Spill Test Date		Piping Installed Date	05/07/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				